

1.933
Sm 63

UNITED STATES DEPARTMENT OF AGRICULTURE
Rural Electrification Administration
Washington 25, D. C.

TECHNICAL STANDARDS COMMITTEES
Month of July 1950

The following is a summary of the changes in the "List of Materials Acceptable For Use on REA-Financed Systems" resulting from decisions of the Technical Standards Committees during the month of July 1950:

1. Page D f-1 - Pin, crossarm, steel

Add Hubbard number 5332 to replace number 71614.

2. Page D m - Clamps, suspension

Add Thomas number 6240A-U under the heading "Overhead Ground Wire - 3/8" High Strength Steel," and number 6244A-U for use with 2/O ACSR conductor.

3. Page D p - Connectors

Remove Burndy catalog numbers BPG625S4C, BPG64A25A, BPG11A25A, and BPG625S2R from pages "D p-1a," "D p-2d," and "D p-3b."

4. Page D aj-2 - Clamp, ground rod

Add Utilities Service number 6696 to replace number 6667.

5. Page D at - Guy Guards

Remove Matthews number 1483 half-round guy guard.

6. Page D av - Conductors, service, (weatherproof)

Add Rome Cable weatherproof conductors as follows:

<u>Manufacturer</u>	<u>MHD Copper</u>	
	<u>Triple-braid (URC)</u>	<u>Neoprene</u>
Rome Cable	TK-URC	RoPrene-753

Page D av-1 - Conductors, bare, copperweld and copperweld-copper

Add Anaconda sizes 2A, 4A, 6A, 8A, 8D, and 9½D.

Add Kennecott size 6A.

2-Technical Standards Committees
Materials List Changes - Month of July 1950

Page D av-2 - Conductors, bare, hard drawn copper (solid and stranded)

Add Anaconda sizes 4/0 x 7, 2/0 x 7, 1/0 x 7, 4, and 6.

Add Kennecott sizes 2/0 x 7, 2 x 3, 4, and 6.

Page D av-3 - Conductors, bare, soft drawn copper

Add Anaconda size 6.

7. Page D sb - Switches, disconnecting, hook operated

Add Matthews type WNM.

8. Page D xx - Service control equipment

Add Murray numbers 1961-35, 1962-35, and 1962-50 to replace numbers 1961-T-35, 1962-T-35, and 1962-T-50, respectively.

9. Page T f-1 - Pin, crossarm, steel

Add Hubbard number 5332 to replace number 71614.

10. Page T m - Clamps, suspension

Add Thomas number 6240A-U.

11. Page T aj-2 - Clamp, ground rod

Add Utilities Service number 6696 to replace number 6667.

12. Page T av-1 - Conductors, bare, copperweld and copperweld-copper

Add Copperweld Steel sizes 4/0 F, 3/0 F, 2/0 F, and 1/0 F.

Add Kennecott size 1/0 F.

Page T av-2 - Conductors, bare, aluminum, concentric-lay-stranded, steel-reinforced (ACSR)

Add Anaconda size 336400 CM 26/7.

13. Page T ej - Clamps, deadend, with socket eye

Add Thomas numbers as follows:

3-Technical Standards Committees
Materials List Changes - Month of July 1950

<u>Manufacturer</u>	<u>Copper & CWC</u>	<u>ACSR</u>	
	4 to 2/0	4 to 1/0	2/0 to 4/0
Thomas	5000	5000	5001

14. Page T sb - Switches, disconnecting, hook operated

Add Matthews type WNM.

15. Page GP - General Plant Items

Add the following:

<u>Manufacturer</u>	<u>Item</u>
Anchor Mfg. Co.	Two Meter Test Trough (horizontal mounting) Catalog No. 672-AT

